



PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC2015010307808287

NAME AND ADDRESS OF THE APPLICANT

Xinchi Electric Group Co., Ltd
Xinguang Industrial Zone, Liushi Town, Yueqing, Zhejiang Province, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

Xinchi Electric Group Co., Ltd
Xinguang Industrial Zone, Liushi Town, Yueqing, Zhejiang Province, P.R.China

NAME AND ADDRESS OF THE FACTORY

Xinchi Electric Group Co., Ltd (V027266)
No 3.Siqian Road, Xinguang Industrial Area, Liushi Town, Yueqing, Zhejiang Province, P.R.China

PRODUCT NAME, MODEL AND SPECIFICATION

Miniature Circuit Breaker

SCB8YF-80,SCB8ZY-80;Ue:AC230(1P+N),AC400V(3P+N);In: 10A、16A、20A、25A、32A、40A、50A、63A、80A;Icn=Ics=10kA(10A~63A)、6kA(80A);Type:C;Poles: 1P+N (with one protected pole,switched N pole)、3P+N (with three protected poles,switched N pole)

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T10963.1-2005

TYPE OF CERTIFICATION SCHEMES

Type testing of product + initial factory inspection + follow up factory inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462143-2019 .

Valid from: May.28,2020

Valid until: Dec.16,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P

President: _____

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

C 0272430