



# 产品认证证书

证书编号：CQC2015010307782075

## 申请人名称及地址

新驰电气集团有限公司  
浙江省乐清市柳市镇新光工业区

## 制造商名称及地址

新驰电气集团有限公司  
浙江省乐清市柳市镇新光工业区

## 生产企业名称及地址

新驰电气集团有限公司(V027266)  
浙江省乐清市柳市镇新光工业区寺前路3号

## 产品名称和系列、规格、型号

### 漏电断路器

SCB8LE-63H; Ue:AC230V(1P+N,2P);AC400V(3P,  
3P+N,4P);In:6A,10A,16A,20A,25A,32A,40A,50A,63A;瞬时脱扣类型:C型;IΔn:30mA/AC  
型;IΔm:3kA;lcs=Icn:10kA;极数:1P+N(不隔离),2P,3P,3P+N(不隔离),4P

## 产品标准和技术要求

GB/T16917.1-2014;GB/T16917.22-2008

## 认证模式

型式试验+初始工厂检查+获证后监督

上述产品符合 CQC11-462143-2019 认证规则的要求，特发此证。

发证日期：2020年05月28日 有效期至：2024年12月16日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

经中国合格评定国家认可委员会认可 CNAS C001-P

主任：\_\_\_\_\_

陆梅



## 中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>

C 0272428



# PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC2015010307782075

## NAME AND ADDRESS OF THE APPLICANT

Xinchi Electric Group Co., Ltd  
Xinguang Industrial Zone, Liushi Town, Yueqing, Zhejiang Province, P.R.China

## NAME AND ADDRESS OF THE MANUFACTURER

Xinchi Electric Group Co., Ltd  
Xinguang Industrial Zone, Liushi Town, Yueqing, Zhejiang Province, P.R.China

## NAME AND ADDRESS OF THE FACTORY

Xinchi Electric Group Co., Ltd (V027266)  
No 3. Siqian Road, Xinguang Industrial Area, Liushi Town, Yueqing, Zhejiang Province, P.R.China

## PRODUCT NAME, MODEL AND SPECIFICATION

Residual Current Operated Circuit-breaker  
SCB8LE-63H; Ue:AC230V(1P+N,2P);AC400V(3P,  
3P+N,4P);In:6A,10A,16A,20A,25A,32A,40A,50A,63A;Type  
C;IΔn:30mA/AC;IΔm:3kA;Ics=Icn:10kA;Poles:1P+N(Not isolated),2P,3P,3P+N(Not isolated),4P

## THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T16917.1-2014;GB/T16917.22-2008

## TYPE OF CERTIFICATION SCHEMES

Type testing of product + initial factory inspection + follow up factory inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462143-2019 .

Valid from: May.28,2020

Valid until: Dec.16,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P

President: \_\_\_\_\_

Lu Mei



## CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China  
<http://www.cqc.com.cn>

C 0272428