



PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC2017010307020297

NAME AND ADDRESS OF THE APPLICANT

Xinchi Electric Group Co., Ltd
Xinguang Industrial Zone, Liushi Town, Yueqing, Zhejiang Province, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

Xinchi Electric Group Co., Ltd
Xinguang Industrial Zone, Liushi Town, Yueqing, Zhejiang Province, P.R.China

NAME AND ADDRESS OF THE FACTORY

Xinchi Electric Group Co., Ltd (V027266)
No 3.Siqian Road, Xinguang Industrial Area, Liushi Town, Yueqing, Zhejiang Province, P.R.China

PRODUCT NAME, MODEL AND SPECIFICATION

Residual Current Operated Circuit-breakers With Integral Overcurrent Protection

SCB8SLE-63、SCB8SLE-63S; SCB8SLE-63; Ue: AC230V; Ui: 500V; Uimp: 4kV; In: 6A, 10A, 16A, 20A, 25A, 32A, 40A, 50A, 63A; IΔn=30mA/50mA/100mA; Rated Residual Operating Type: AC 型, Electronic; IΔn: t≤0.1s; IΔm: 2000A; Type of Instantaneous Tripping Current: C 型; Icn=Ics: 6000A; Poles: 1P+N (With one protective poles,With one protective pole), 2P; Suitable for insulation; SCB8SLE-63S; Ue: AC230V; Ui: 500V; Uimp: 4kV; In: 25A, 32A, 40A, 50A, 63A; IΔn=50mA/100mA; Rated Residual Operating Type: AC 型, Electronic, 延时型; IΔn 动作时间: t≤0.2s; IΔm: 2000A; Type of Instantaneous Tripping Current: C 型; Icn=Ics: 6000A; Poles: 1P+N (With one protective poles,With one protective pole), 2P; Suitable for insulation

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T16917.1-2014;GB/T16917.22-2008

TYPE OF CERTIFICATION SCHEMES

Type testing of product + initial factory inspection + follow up factory inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462143-2019 .

Valid from: May.28,2020

Valid until: Nov.08,2022

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

President: _____

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China
<http://www.cqc.com.cn>

C 0272461