



中国国家强制性产品认证证书

证书编号：2024010307656876

认证委托人名称及地址
新驰电气集团有限公司
浙江省乐清市柳市镇新光工业区

生产者名称及地址
新驰电气集团有限公司
浙江省乐清市柳市镇新光工业区

生产企业名称及地址
新驰电气集团有限公司
浙江省乐清市柳市镇新光工业区寺前路3号

产品名称和系列、型号、规格
断路器

SL7-63; Ue: AC250V(1P), AC415V(2P、3P、4P); DC440V、DC550V、DC800V(2P 外形), DC800V、DC1000V、DC1200V(4P 外形) Ui: 500V(AC), 1200V (DC); Uimp: 6kV; In: 6A, 10A, 16A, 20A, 25A, 32A, 40A, 50A, 63A; 过电流脱扣器类型: 热磁式; Ics: 4.5kA; Icu: 6kA; 选择性类别: A 类; 极数: 1P, 2P, 3P, 4P; 直流产品接线方式: 2P 外形, 4P 外形; 具体接线方式见附页; 产品适用于隔离

产品标准和技术要求
GB/T 14048.2-2020

上述产品符合《强制性产品认证实施规则 低压电器 低压元器件》
(CNCA-C03-02:2024) 的要求, 特发此证。

发证日期: 2024 年 07 月 12 日 有效期至: 2029 年 07 月 11 日

证书信息和有效性可扫描下方二维码或登录发证机构网站查验,
也可在认监委网站 (www.cnca.gov.cn) 查询。



签发:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司






中国国家强制性产品认证证书


证书编号: 2024010307656876

证书附页: 第 1 页 共 2 页

直流接线图:



2P 外形
DC1200V (4P 外形)



DC800V, DC1000V (4P 外形)

型号的解释:

本页为证书附页, 应与证书主页同时使用。



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司



证书附页：第 2 页 共 2 页

企业代号



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO.: 2024010307656876

NAME AND ADDRESS OF THE APPLICANT

Xinchi Electric Group Co., Ltd.
Xinguang Industrial Zone, Liushi Town, Yueqing, Zhejiang Province, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

Xinchi Electric Group Co., Ltd.
Xinguang Industrial Zone, Liushi Town, Yueqing, Zhejiang Province, P.R.China

NAME AND LOCATION OF THE FACTORY

Xinchi Electric Group Co., Ltd.
No.3 Siqian Road, Xinguang Industrial Area, Liushi Town, Yueqing, Zhejiang Province, P.R.China

PRODUCT NAME,MODEL AND SPECIFICATION

Circuit-breaker

SL7-63 ; Ue : AC250V(1P) , AC415V(2P、 3P、 4P) ; DC440V、 DC550V、 DC800V(2P shape) , DC800V、 DC1000V、 DC1200V(4P shape) Ui : 500V(AC) , 1200V (DC) ; Uimp : 6kV ; In : 6A , 10A , 16A , 20A , 25A , 32A , 40A , 50A , 63A ; Over-current Release Type : thermo-magnetic ; Ics : 4.5kA ; Icu : 6kA ; Selective category : A ; pole : 1P , 2P , 3P , 4P ; DC wiring method 2P shape , 4P shape , Please refer to the attached page for specific wiring methods ; Suitable for isolation

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.2-2020

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO. CNCA-C03-02:2024).

Valid from: Jul.12,2024

Valid until: Jul.11,2029

The certificate information and validity could be checked by scanning the QR code below or logging in to the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.








CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO. : 2024010307656876

Appendix: Page 1 of 2

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

直流接线图：



2P 外形

DC800V, DC1000V(4P 外形)

DC1200V(4P 外形)

Type description:

This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO. : 2024010307656876

Appendix: Page 2 of 2

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

SL	7	- 63	C	☐	
					额定电流 (A)
					瞬时脱扣特性类别, $I_i=10I_n$
					壳架等级额定电流 (A)
					设计序号
					企业代号

This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.