



中国国家强制性产品认证证书

证书编号: 2024010307742273

认证委托人名称及地址
新驰电气集团有限公司
浙江省乐清市柳市镇新光工业区

生产者名称及地址
新驰电气集团有限公司
浙江省乐清市柳市镇新光工业区

生产企业名称及地址
新驰电气集团有限公司
浙江省乐清市柳市镇新光工业区寺前路3号

产品名称和系列、型号、规格
电能表外置漏电断路器

SCB8ZLE-125M Ue: AC230V(1P+N, 2P), AC400V(3P, 3P+N, 4P); Uimp: 6kV; Ui: 500V;
In: 63A、80A、100A、125A; I Δ n: 30mA、50mA、75mA、100mA、300mA、500mA; 额定剩
余动作类型: AC 型, 电子式; I Δ m=2000A; 瞬时脱扣类型: C 型; Icn=Ics=6000A; 极数: 1P+N(带
一个保护极, N 极可开闭), 2P, 3P, 3P+N(带三个保护极, N 极可开闭), 4P; 产品适用于隔离;
控制方式: 远程半自动和远程全自动控制方式; Us: AC220V

产品标准和技术要求
GB/T 16917.1-2014; GB/T 16917.22-2008

上述产品符合《强制性产品认证实施规则 低压电器 低压元器件》
(CNCA-C03-02:2024) 的要求, 特发此证。

发证日期: 2024 年 12 月 24 日 有效期至: 2029 年 12 月 23 日

证书信息和有效性可扫描下方二维码或登录发证机构网站查验,
也可在认监委网站 (www.cnca.gov.cn) 查询。



签发:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO.: 2024010307742273

NAME AND ADDRESS OF THE APPLICANT

Xinchi Electric Group Co., Ltd.
Xinguang Industrial Zone, Liushi Town, Yueqing, Zhejiang Province, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

Xinchi Electric Group Co., Ltd.
Xinguang Industrial Zone, Liushi Town, Yueqing, Zhejiang Province, P.R.China

NAME AND LOCATION OF THE FACTORY

Xinchi Electric Group Co., Ltd.
No 3.Siqian Road, Xinguang Industrial Area, Liushi Town, Yueqing, Zhejiang Province, P.R.China

PRODUCT NAME,MODEL AND SPECIFICATION

External leakage circuit breaker for energy meter

SCB8ZLE-125M Ue: AC230V(1P+N, 2P), AC400V(3P, 3P+N, 4P); Uimp: 6kV; Ui: 500V; In: 63A, 80A, 100A, 125A;
IΔn: 30mA, 50mA, 75mA, 100mA, 300mA, 500mA; Rated residual action type: AC type, electronic type; IΔm=2000A;
Instantaneous trip type: Type C; Icn=Ics=6000A; Number of poles: 1P+N(with a protection pole, N pole can be opened and closed,), 2P, 3P, 3P+N(with three protection poles, N pole can be opened and closed), 4P; suitable for isolation;Control mode: remote semi-automatic and remote automatic control mode; Us: AC220V

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 16917.1-2014;GB/T 16917.22-2008

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO. CNCA-C03-02:2024).

Valid from: Dec.24,2024

Valid until: Dec.23,2029

The certificate information and validity could be checked by scanning the QR code below or logging in to the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

